



0086-CPR-595350



Leiths (Scotland) Ltd
Achilty Quarry, Contin, Strathpeffer IV14 9EG
Telephone: 01997 421122
Fax: 01997 421145

13

Certificate No. ACQ-B204b

BS EN 13108 – 1

**Asphalt Concrete for roads and other trafficked areas
B204b AC 10 close surf 100/150 rec - Achilty Asphalt Plant**

General requirements

Temperature of the mixture		120 °C to 170 °C
Grading (passing)	14 mm test sieve	100 %
	10 mm test sieve	100 %
	6,3 mm test sieve	65 %
	2 mm test sieve	30 %
	1 mm test sieve	22 %
Binder content	0,063 mm test sieve	6,0 %
		5,2 (5,2%)

Leiths (Scotland) Ltd confirms that the asphalt concrete referred to in this certificate complies with the requirements of BS EN 13108 – 1, including Annex ZA

Authorised by:

N. Anderson. Group Technical Director

Date Valid from
Date Valid to
Date of Certificate Issue

01/03/2013
Currently Valid
25 June 2013