



0086-CPR-595350



Leiths (Scotland) Ltd
Achilty Quarry, Contin, Strathpeffer IV14 9EG
Telephone: 01997 421122
Fax: 01997 421145

13

Certificate No.: ACQ - B108

BS EN 13108 – 1

Asphalt Concrete for roads and other trafficked areas

B108 AC 20 dense bin 40/60 rec - Achilty Asphalt Plant

General requirements

Temperature of the mixture		130 °C to 190 °C
Grading (passing)	31,5 mm test sieve	100 %
	20 mm test sieve	100 %
	14 mm test sieve	80 %
	6,3 mm test sieve	49 %
	2 mm test sieve	30 %
	0,250 mm test sieve	15 %
	0,063 mm test sieve	7,0 %
Binder content		4,6 (4,5%)

Leiths (Scotland) Ltd confirms that the asphalt concrete referred to in this certificate complies with the requirements of BS EN 13108 – 1, including Annex ZA

Authorised by:

N. Anderson. Group Technical Director

Date Valid from
Date Valid to
Date of Certificate Issue

01/03/2013
Currently Valid
25 June 2013