



0086-CPR-595350



Leiths (Scotland) Ltd  
Bluehill Quarry, Dufftown, Keith. AB55 4BW  
Telephone: 01340 820200  
Fax: 01340 820890

**13**

**Certificate No. BHQ-B451**

**BS EN 13108 – 4**

**Hot Rolled Asphalt**

**B451 HRA 30/14 C surf 40/60 des - Bluehill Asphalt Plant**

**General requirements**

Temperature of the mixture		150 °C to 190 °C
Grading (passing)	20 mm test sieve	100 %
	14 mm test sieve	100 %
	10 mm test sieve	81 %
	2 mm test sieve	66 %
	0,500 mm test sieve	37 %
	0,250 mm test sieve	24 %
	0,063 mm test sieve	9,0 %
Binder content		7,2 (7,2 %)

**Leiths (Scotland) Ltd confirms that the asphalt concrete referred to in this certificate complies with the requirements of BS EN 13108 – 4, including Annex ZA**

**Authorised by:**

*N. Anderson. Group Technical Director*

Date Valid from  
Date Valid to  
Date of Certificate Issue

01/03/2013  
Currently Valid  
19 June 2013