



0086-CPR-595350



Leiths (Scotland) Ltd
Loch-Hills Quarry, Parkhill, Aberdeen. AB21 7AT
Telephone: 01224 774422
Fax: 01224 772444

13

Certificate No. LHCP-B205

BS EN 13108 – 1

**Asphalt Concrete for roads and other trafficked areas
B205 AC 10 close surf 160/220 rec - Loch-Hills Asphalt Plant**

General requirements

Temperature of the mixture		110 °C to 170 °C
Grading (passing)	14 mm test sieve	100 %
	10 mm test sieve	98 %
	6,3 mm test sieve	68 %
	2 mm test sieve	31 %
	1 mm test sieve	22 %
Binder content	0,063 mm test sieve	6,0 %
		5,2 (5,2%)

Leiths (Scotland) Ltd confirms that the asphalt concrete referred to in this certificate complies with the requirements of BS EN 13108 – 1, including Annex ZA

Authorised by:

N. Anderson. Group Technical Director

Date Valid from	01/03/2013
Date Valid to	Currently Valid
Date of Certificate Issue	25 June 2013

